



NOTE:

1. NO GALV. PIPE & FITTINGS SHALL BE USED
2. LOCATE STANDPIPE & VALVE AS DIRECTED BY THE ENGINEER

REV. NO.	PREPARED BY:	SUMMIT WATER DISTRIBUTION CO.	STANDARD DWG. NO.
1. 8/20/97 2. 12/31/15	 Bowen Collins & Associates, Inc. CONSULTING ENGINEERS	<h1>2' BLOWOFF VALVE DETAIL</h1>	<h1>10</h1>