

The cover features a white background with a large blue triangle in the top-left corner and a dark blue triangle in the bottom-left corner. The SWMDC logo is centered in the upper half, and the report title is centered below it. A vertical white line is on the left side.

SWMDC

WATER QUALITY REPORT 2024

WHAT'S INSIDE:

- Test Results
- What is Cross Connection?
- Source Protection
- How You Can Help

SWDC is pleased to present to you, our customer, the most current Drinking Water Quality report. This report is designed to inform you about the quality of the water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water.

SWDC provides its consumers with both ground and surface water. Our water sources are eight wells, Park City Water and Mountain Regional SSD. Our wells are listed as New Rest Stop, Jeremy Ranch, White Pine, Church, Old F-7, U224, New F7, and Hi-Ute.
Lead Service Line Inventory

Service Line Inventory

Most of us have heard that lead water pipes can lead to adverse health effects. To ensure water safety, the EPA is requiring water systems to develop a public lead service line inventory and create a plan for identifying and mitigating lead service lines. SWDC has completed an initial lead service line inventory, which is publicly available and can be accessed at www.summitwater.us/service-line-survey.

Source Protection

The Drinking Water Source Protection Plan for SWDC is available for your review on our website. It contains information about source protection zones, potential contamination sources and management strategies to protect our drinking water. Our sources have been determined to have a medium level of susceptibility from potential contamination sources. We have also developed management strategies to further protect our sources from contamination. Please contact us if you have questions or concerns about our source protection plan.

Cross Connection & Backflow Prevention

There are many connections to our water distribution system. When connections are properly installed and maintained, the concerns are very minimal. However, unapproved and improper piping changes or connections can adversely affect not only the availability, but also the quality of the water. A cross connection may let polluted water or even chemicals mingle into the water supply system when not properly protected. This not only compromises the water quality but can also affect your health. So, what can you do? Do not make or allow improper connections at your home. Even that unprotected garden hose lying in the puddle next to the driveway is a cross connection. The unprotected lawn sprinkler system after you have fertilized or sprayed is also a cross connection. When the cross connection is allowed to exist at your home, it will affect you and your family first. Utah state law requires irrigation and fire suppression systems to be equipped with backflow prevention devices. These devices are required to be tested annually by a certified backflow tester. Please visit the Backflow Prevention page on our website for additional information, including answers to commonly asked questions.

Potential Health Risks

Drinking water, including bottled water, may reasonably be expected to contain at least a small amount of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and the potential health effects can be obtained by calling the Environmental protection Agency's (EPA) Safe Drinking Water Hotline at (800-426-4791). The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, reservoirs, springs and wells.

As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agricultural, urban stormwater runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Lead

If present, lead can cause serious health problems, especially for pregnant women and young children. Corrosion of pipes, plumbing fittings and fixtures may cause metals, including lead and copper, to enter drinking water. To assess corrosion of lead and copper, SWDC conducts tap sampling for lead and copper at selected sites every three years. SWDC conducted twenty lead samples during 2023. Sampling results can be obtained by requesting them at summitwater@swdc.us.

SWDC is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. Lead in drinking water is primarily from material and components associated with service lines and home plumbing. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. If your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. Lead in drinking water is rarely the sole cause of lead poisoning, but it can add to a person's total lead exposure. All potential sources of lead in the household should be identified and removed, replaced or reduced. If you are concerned about lead in your water, you may wish to have your water tested, please contact Laramie Simmons with SWDC at 435-649-7324. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>. Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised people such as people with cancer undergoing chemotherapy, people who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers about drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

SWDC Text Notifications

To enroll in SWDC text notifications text SWDC to 67332. These notifications allow you to receive information when water will be shut off for emergency repairs and for leak alerts. Login to your customer portal to customize additional notifications.

Customer Service

The employees at SWDC work around the clock to provide top quality water for every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. We want our valued customers to be informed about their water utility, please feel free to attend any of our regularly scheduled meetings. They are held on the first Wednesday of each month, please contact the office for more information. If you have any questions about this report or concerning your water utility, please contact us at 435-649-7324 or summitwater@swdc.us.

TEST RESULTS: SWDC routinely monitors contaminants in our drinking water in accordance with the Federal and Utah State laws. The following table shows the results of our monitoring for 2024. It is important to remember that all water sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health.

Contaminant	Violation Y/N	Level Detected ND/Low-High	Unit Measurement	MCLG	MCL	Date Sampled	Likely Source of Contamination
Microbiological Contaminants							
Total Coliform Bacteria	N	ND	N/A	0	Presence of coliform bacteria in 5% of monthly samples	2024	Naturally present in the environment
Fecal coliform and <i>E.coli</i>	N	ND	N/A	0	If a routine sample and repeat sample are total coliform positive, and one is also fecal coliform or <i>E. coli</i> positive	2024	Human and animal fecal waste
Turbidity for Ground Water	N	3	NTU	N/A	5	2024	Soil runoff
Turbidity for Surface Water	N	0.32	NTU	N/A	0.5 in at least 95% of the samples and must never exceed 5.0	2024	Soil Runoff (highest single measurement & the lowest monthly percentage of samples meeting the turbidity limits)
Inorganic Contaminants							
Antimony	N*	ND-10	ppb	6	6	2024	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
Arsenic	N	2-3	ppb	0	10	2024	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium	N	30	ppb	2000	2000	2024	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Cadmium	N	0.2	ppb	5	5	2024	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints
Copper a. 90% results b. # of sites that exceed the AL	N	a.0.237 b.0	ppm	1.3	AL=1.3	2023	Corrosion of household plumbing systems; erosion of natural deposits
Cyanide	N	3	ppb	200	200	2024	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
Fluoride	N	197	ppb	4000	4000	2024	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories

Lead a. 90% results b. # of sites that exceed the AL	N	a. 4 b.0	ppb	0	AL=15	2023	Corrosion of household plumbing systems, erosion of natural deposits
Nickel	N	6-8	Ppb	100	100	2024	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
Nitrate (as Nitrogen)	N	1	ppm	10	10	2024	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium	N	1-3	ppb	50	50	2024	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium	N	5-113	ppm	None set by EPA	None set by EPA	2024	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills.
Sulfate	N	4-271	ppm	1000	1000	2024	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills, runoff from cropland
TDS (Total Dissolved solids)	N	184-1348	ppm	2000	2000	2024	Erosion of natural deposits
Disinfection By-products							
TTHM [Total trihalomethanes]	N	14-19	ppb	0	80	2024	By-product of drinking water disinfection
Haloacetic Acids	N	11-16	ppb	0	60	2024	By-product of drinking water disinfection
Radioactive Contaminants							
Alpha emitters	N	5-10	pCi/l	0	15	2023	Erosion of natural deposits
Combined Radium	N	1	pCi/l	0	5	2023	Erosion of natural deposits
Radium 226	N	0.109-0.166	pCi/l	0	5	2023	Erosion of natural deposits
Radium 228	N	0.57-1	pCi/l	0	5	2023	Erosion of natural deposits

Water Conservation:

Water conservation measures are an important first step in protecting our water supply. Such measures not only save the supply of our source water, but you can also save money by reducing your water bill. Here are a few suggestions:

Conservation in your home:

- Take shorter showers
- Run the dishwasher only when full
- Soak dishes before washing
- Fix leaking faucets, pipes, toilets, etc.
- Wash full loads of laundry
- Replace old fixtures
- Do not use the toilet for trash disposal
- Install water saving devices

Conserve Outdoors:

- Water the lawn and garden in the early morning or late evening
- Use mulch around plants and shrubs
- Repair leaks in faucets and hoses
- Use water-saving nozzles
- Use water from a bucket to wash your car and save the hose for rinsing

Table Definitions:

In the test results table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

ND/Low - High - For water systems that have multiple sources of water, the Utah Division of Drinking Water has given water systems the option of listing the test results of the constituents in one table, instead of multiple tables. To accomplish this, the lowest and highest values detected in the multiple sources are recorded in the same space in the report table.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/l) - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Nanograms per liter (nanograms/l) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) or Picograms per liter (picograms/l) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Million Fibers per Liter (MFL) - million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. **Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Date - Because of required sampling time frames i.e. yearly, 3 years, 4 years and 6 years, sampling dates may seem out-dated.

Waivers (W) - Because some chemicals are not used or stored in areas around drinking water sources, some water systems have been given waivers that exempt them from having to take certain chemical samples, these waivers are also tied to Drinking Water Source Protection Plans.